



OFFICE OF THE DISTRICT FIRE OFFICER,
KARNATAKA FIRE & EMERGENCY SERVICES,
ANJANPURA FIRE STATION, BENGALURU-560 108.



C.No: 20/DFO/AFS/BLR/RFSCR-21/2024.

Dated: 03-04-2024

"Annexure-2"

To,

The Secretary,
R.V College of Engineering,
R.V Educational Institutions,
R.V Vidyaniketana Post, Mysore road,
Bengaluru – 560059.

Sir,

Sub: Issue of **"Renewal of Fire Safety Compliance Certificate"** with respect to fire prevention, fighting and evacuation measures maintained at "M/s. RV College of Engineering, RV Educational Institutions, 1. Administrative block, 2. Civil Engineering block, 3. Electrical & Electronics Engineering block, 4. Electronics & Communication Engineering block, 5. Computer Science block, 6. Telecommunication Engineering block, 7. Class room complex, 8. Chemical Engineering block, 9. Library block, 10 Aero Space & Information Science, 11 Bio Technology & Electronics & Instrumentation Engineering, 12. Master of computer application block, 13. Industrial Engineering & Management block, 14. Mechanical engineering block, 15. Mechanical post graduate block, 16. Cauvery hostel block, 17 Diamond jubilee girls hostel block, 18. Chamundi hostel block, 19. Sir M Vishveshwaraiah hostel block. R.V Vidyaniketana post, Mysore road, Bengaluru – 560 059."

Ref: 1) FSR C.No:936(2)/CFO/Bng-East/2020; Date: 22/12/2021
2) CC C.No:1528(2)/CFO/Bng-East/2020; Date: 19/01/2022
3) RCC C.No: 12/DFO/SRFS/Bng/2023; Date: 27/03/2023
3) Your request letter dated: 20-03-2024

<<<@ @ @ @ @>>>

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises of "M/s RV College of Engineering, RV Educational Institutions, RV Vidyanikethana Post, Mysore road, Bengaluru – 560 059." with a condition to fulfill all the recommendations stipulated in fire safety recommendation and compliance the same within 3 months and as per reference (2), the Fire Safety Compliance Report was issued for the same.



SKV/7
GTA

With reference cited (3) above, the management of 'RV College of Engineering' had requested for the renewal fire safety compliance report from our department. In this regard the above school building was inspected by me on 25-03-2024 to check the compliance of all the recommendations stipulated in fire safety recommendation & on inspection it was found that all the recommendations stipulated in fire safety recommendation has been complied.

Under the above circumstance the Karnataka Fire & Emergency Services Department is Renewing the "Fire Safety Compliance Certificate" of "M/s. RV College of Engineering, RV Educational Institutions, 1. Administrative block, 2. Civil Engineering block, 3. Electrical & Electronics Engineering block, 4. Electronics & Communication Engineering block, 5. Computer Science block, 6. Telecommunication Engineering block, 7. Class room complex, 8. Chemical Engineering block, 9. Library block, 10 Aero Space & Information Science, 11 Bio Technology & Electronics & Instrumentation Engineering, 12. Master of computer application block, 13. Industrial Engineering & Management block, 14. Mechanical Engineering block, 15. Mechanical post, graduate block, 16. Cauvery hostel block, 17 Diamond jubilee girls hostel block, 18. Chamundi hostel block, 19. Sir M Vishveshwaraiah hostel block. R.V Vidyaniketana post, Mysore road, Bengaluru – 560 059." subject to proper maintenance of firefighting installations in the good working conditions, one generator of suitable capacity to supply alternative power for staircase lighting, corridor lighting etc., in the event of failure of electricity supply in the building and arrange for 40% of staffs / employees training within 03 months from the date of issue of this report.

"This report is valid for only one year from the date of issue and is renewable without fail".



Yours faithfully

DISTRICT FIRE OFFICER
Anjanapura Fire Station,
BANGALORE-560 108